



**KEYED NOTES:**

- 1 LANL SUPPORT SERVICES SUBCONTRACTOR (SSS) WILL NUMBER (METAL STAMP) THE FIRE HYDRANT AND VALVE BOX LID.
- 2 PAINT HYDRANT BONNET BLACK AND ATTACH LABEL - CAUTION: NON-POTABLE WATER, DO NOT DRINK. [REQUIRED ONLY FOR HYDRANTS SERVED BY NON-POTABLE WATER ON DEDICATED FIRE LOOPS.]

DRAWING DEVELOPED FOR ML-3/ML-4 PROJECTS. FOR ML-1/ML-2, ADDITIONAL REQUIREMENTS AND QA REVIEWS ARE REQUIRED. (REMOVE THIS NOTE WHEN INSERTED INTO A DRAWING PACKAGE).

**FIRE HYDRANT DETAIL**  
SCALE: NONE

**NOTES FOR DESIGNER:** (DO NOT INCLUDE ON CONSTRUCTION DRAWINGS)

- 1. SEE SHEET 2.

2	1-18-06	U	DY	REVISED TITLE BLOCK DATA AND ADTS - ENGINEERING LOGO.	RP	EH	MS	EH	TO	
1	8/23/02	U		GENERAL REVISION AND DWG. NO. WAS ST6110.	RP	EH	MS	EH	TO	
NO	DATE	CLASS	REV	ADD	DESCRIPTION	OWN	DSGN	CHKD	SUB	APP

**ENGINEERING STANDARDS PROGRAM**

<b>ENGINEERING STANDARDS MANUAL</b>		DRAWN	R.PEARSON
		DESIGN	E.HOTH
		CHECKED	M.SMITHOUR
FIRE HYDRANT GATE SHUT-OFF VALVE DETAIL		DATE	6-28-99
BLDG X		TA-X	
SUBMITTED		APPROVED FOR RELEASE	
DISCIPLINE POC: E. HOTH		STANDARDS MANAGER: TOBIN ORUCH	
		PO Box 1663 Los Alamos, New Mexico 87545	1 OF 2
CLASSIFICATION: U	REVIEWER: LARRY BAYS	DATE:	
PROJECT ID	DRAWING NO	REV	
<b>CHAPTER 3</b>		<b>ST-G3010-4</b>	<b>2</b>

© 2006 Los Alamos National Laboratory. All rights reserved. This document is the property of Los Alamos National Laboratory.