



SAFETY SHOWER WITH EYEWASH DETAIL

SCALE: NONE

NOTES FOR DESIGNER: (DO NOT INCLUDE ON CONSTRUCTION DRAWINGS)

1. SEE SHEET 4 AND 5.

KEYED NOTES:

- 1 FURNISHED WITH EMERGENCY EQUIPMENT.
- 2 PROVIDE GUIDE PLATE WHEN PULL ROD PENETRATES CEILING.
- 3 VALVE TO BE ACCESSIBLE FOR MAINTENANCE.
- 4 EMERGENCY SIGN(S).
- 5 LOCATE PULL ROD AS CLOSE TO WALL AS POSSIBLE.
- 6 THERMOSTATIC MIXING VALVE IN CABINET W/ DOOR, WALL OR RECESSED MOUNTED.
- 7 LOCATE ISOLATION BALL VALVES (3 REQ'D) WITHIN CABINET.
- 8 TEPID WATER SUPPLY.

DRAWING DEVELOPED FOR ML-3/
ML-4 PROJECTS. FOR ML-1/
ML-2, ADDITIONAL REQUIREMENTS
AND QA REVIEWS ARE REQUIRED.
(REMOVE THIS NOTE WHEN IN-
SERTED INTO A DRAWING PACK-
AGE).

3	8-14-03	U	EDITORIAL CHANGES & DWG NO. WAS ST6000.	RP	JM	RR	GG	TO
2	10-25-02	U	REMOVED THE EYEWASH DRAIN PIPING.	RP	RR	GG	GG	TO
1	9-6-02	U	GENERAL REVISION, ADDED PWH PIPING AND MIXING VALVE.	RP	RR	GG	GG	TO
NO	DATE	CLASS REV	DESCRIPTION	DWN	DSGN	CHKD	SUB	APP
				FACILITY & WASTE OPERATIONS DESIGN ENGINEERING CONSTRUCTION SERVICES				
ENGINEERING STANDARDS MANUAL				DRAWN R.PEARSON				
				DESIGN R.ROMERO				
				CHECKED G.GREWAL				
BLDG X SUBMITTED				TA-X APPROVED FOR RELEASE	DATE 6-28-99			
DISCIPLINE POC: GURINDER GREWAL				STANDARDS MANAGER: TOBIN ORUCH				
				SHEET 2				
				P.O. Box 1663 Los Alamos, New Mexico 87545				
CLASSIFICATION U				REVIEWER LARRY BAYS		DATE		
PROJECT ID CHAPTER 6				DRAWING NO ST-D2010-1		REV 3		