

	8	7	6	5	4	3	2	1
H								
G								
F								
E								
D								
C								
B								
A								

NOTES FOR DESIGNER: (DO NOT INCLUDE ON CONSTRUCTION DRAWINGS)

13. WASTE LINES FROM EYEWASH OR EYE/FACE WASH UNITS SHALL DISCHARGE ONTO FLOOR (PER FWO-UI AND RRES-WQH).
14. LOCATE CENTERLINE OF EMERGENCY EQUIPMENT A MINIMUM OF 7 FEET FROM ELECTRICAL OR MECHANICAL EQUIPMENT (I.E. TRANSFORMERS, COMPRESSORS AND SIMILAR ITEMS). EQUIP ELECTRICAL OUTLETS WITHIN 6 FEET WITH A GFCI.
15. AN ALARM SYSTEM MAY HAVE TO BE INSTALLED WHEN THE EMERGENCY UNITS ARE INSTALLED IN REMOTE AREAS OR IN HAZARDOUS LOCATIONS WHERE THERE ARE FEW PEOPLE. HSR-5 AND THE USER WILL MAKE THIS DETERMINATION.
16. ALLOW A MINIMUM UNOBSTRUCTED AREA OF 34" IN DIAMETER WHEN A SHOWER PRIVACY SCREEN (2, 3, OR 4 SIDED) IS REQUESTED BY THE USER.
17. CONSIDER CORROSION RESISTANT MATERIAL IF EMERGENCY EQUIPMENT IS INSTALLED IN HARSH ENVIRONMENTS.
18. PORTABLE EYEWASHES MEETING STANDARD ANSI/ISEA Z358.1-1998 MAY BE USED ONLY FOR TEMPORARY OR FIELD OPERATIONS OR WHERE POTABLE WATER IS NOT AVAILABLE.

DRAWING DEVELOPED FOR ML-3/
ML-4 PROJECTS. FOR ML-1/
ML-2, ADDITIONAL REQUIREMENTS
AND QA REVIEWS ARE REQUIRED.
(REMOVE THIS NOTE WHEN IN-
SERTED INTO A DRAWING PACK-
AGE).

NO	DATE	CLASS REV	DESCRIPTION	DWN	DSGN	CHKD	SUB	APP
3	8-14-03	U	EDITORIAL CHANGES & DWG NO. WAS ST6000.	RP	JM	RR	GG	TO
2	10-25-02	U	REVISED NOTES 13, 15, AND 18.	RP	RR	GG	GG	TO
1	9-6-02	U	REVISED NOTES.	RP	RR	GG	GG	TO

FACILITY & WASTE OPERATIONS	
DESIGN ENGINEERING CONSTRUCTION SERVICES	
ENGINEERING STANDARDS MANUAL	DRAWN R.PEARSON
EMERGENCY EQUIPMENT DETAIL DESIGN NOTES	DESIGN R.ROMERO
	CHECKED G.GREWAL
	DATE 6-28-99
BLDG X	TA-X
SUBMITTED	APPROVED FOR RELEASE
DISCIPLINE FOC: GURINDER GREWAL	STANDARDS MANAGER: TOBIN GRUCH
SHEET	
5	
5 OF 5	
CLASSIFICATION U	REVIEWER LARRY BAYS
PROJECT ID	DATE
DRAWING NO	REV
CHAPTER 6	ST-D2010-1
6	3