



**KEYED NOTES:**

- 1 INSTALL ABSORBENT PAD (FURNISHED WITH SEPARATOR) UNDER TORPEDO. LAY DIAGONALLY.
- 2 THROTTLE GLOBE VALVE TO REGULATE AIR FLOW TO PREVENT TORPEDO SEPARATOR FROM BLOWING OFF.
- 3 AUTOMATIC DRAIN VALVE FURNISHED WITH REFRIGERATED DRYER.
- 4 SECURE CABLE WITH WIRE TIE WRAPS (FURNISHED WITH TORPEDO) TO SUITABLE ANCHOR POINT.

DRAWING DEVELOPED FOR ML-3/ML-4 PROJECTS. FOR ML-1/ML-2, ADDITIONAL REQUIREMENTS AND QA REVIEWS ARE REQUIRED. (REMOVE THIS NOTE WHEN INSERTED INTO A DRAWING PACKAGE).

**COMPRESSED AIR COMPONENT DETAIL**  
SCALE: NONE

NOTES FOR DESIGNER: (DO NOT INCLUDE ON CONSTRUCTION DRAWINGS)  
1. SEE SHEET 1.

3	8-13-03	U	EDITORIAL CHANGES AND DWG NO. WAS STRUCK.	RP	JM	RR	OG	TO	
2	8-8-02	U	ADDED "ML" NOTE.	RP	JR	OG	OG	TO	
1	2-7-01	U	REVISED FLOW DIAGRAM, NOTES, AND ADDED SHEET 3 AND 4.	RP	JR	RR	TO	TO	
NO	DATE	CLASS REV	ADD	DESCRIPTION	OWN	DSGN	CHKD	SUB	APP

**ENGINEERING STANDARDS PROGRAM**

**ENGINEERING STANDARDS MANUAL**

COMPRESSED AIR COMPONENT DETAIL  
LUBRICATED COMPRESSOR, REMOTE RECEIVER

BLDG X TA-X DATE 2-7-01

APPROVED FOR RELEASE  
STANDARDS MANAGER: TOBIN ORUCH

Los Alamos NATIONAL LABORATORY PO Box 1663 Los Alamos, New Mexico 87545

CLASSIFICATION: U REVIEWER: LARRY BAYS DATE: 3 OF 4

PROJECT ID: CHAPTER 6 DRAWING NO: ST-D2090-1 REV: 3

© 2003 Los Alamos National Laboratory. All rights reserved. Approved for release under E.O. 13526, Dec. 17, 2009. Approved for release under E.O. 13526, Dec. 17, 2009.