



**KEYED NOTE:**  
 ① AUTOMATIC DRAIN VALVE FURNISHED WITH REFRIGERATED DRYER.

**COMPRESSED AIR COMPONENT DETAIL**  
 SCALE: NONE

**NOTES FOR DESIGNER:** (DO NOT INCLUDE ON CONSTRUCTION DRAWINGS)  
 1. SEE SHEET 1.

DRAWING DEVELOPED FOR ML-3/ML-4 PROJECTS. FOR ML-1/ML-2, ADDITIONAL REQUIREMENTS AND QA REVIEWS ARE REQUIRED. (REMOVE THIS NOTE WHEN INSERTED INTO A DRAWING PACKAGE).

3	8-13-03	U		EDITORIAL CHANGES AND DWG NO. WAS STROG.	RP	JM	RR	GG	TO
2	9-8-02	U		ADDED "ML" NOTE.	RP	JR	GG	GG	TO
1	2-7-01	U		REVISED FLOW DIAGRAM, NOTES, AND ADDED SHEET 3 AND 4.	RP	JR	RR	TO	TO
NO	DATE	CLASS	REV	DESCRIPTION	OWN	DSGN	CHKD	SUB	APP

**ENGINEERING STANDARDS PROGRAM**

**ENGINEERING STANDARDS MANUAL**

DRAWN	R.PEARSON
DESIGN	J.WATLUFF
CHECKED	R.ROMERO
DATE	2-7-01

BLDG X TA-X

DISCIPLINE POC: GURINDER GREWAL STANDARDS MANAGER: TOBIN ORUCH

**Los Alamos NATIONAL LABORATORY** PO Box 1663 Los Alamos, New Mexico 87545

CLASSIFICATION: U REVIEWER: LARRY BAYS DATE: PROJECT ID: DRAWING NO: SHEET: 4 OF 4

**CHAPTER 6 ST-D2090-1** REV 3

C:\Users\Engineering\Breadboard\Doc\_Material [L]BDD\3 - Approved\CFR-2009-11\02.dwg, 09/18/03 @ 11:05 000000