



KEYED NOTES:

- 1 CONNECT SENSING LINE TO A STRAIGHT SECTION OF PIPING, MINIMUM 10 PIPE DIAMETERS OR 24" WHICHEVER IS GREATER.
- 2 PROVIDE 1/2" VALVE IN BOTTOM OF CONDENSATE LINE.
- 3 3/4" BYPASS FOR INITIAL WARM-UP.
- 4 FIRST SHUTOFF VALVE INSIDE BUILDING.
- 5 ON STEAM SERVICES, PROTECT THE PRESSURE GAUGE WITH A PIGTAIL SIPHON.
- 6 FIRST SHUTOFF VALVE AND TRAP SHOULD BE WITHIN 10 FEET OF THE EXTERIOR WALL ENTRY POINT.

DRAWING DEVELOPED FOR ML-3/ML-4 PROJECTS. FOR ML-1/ML-2, ADDITIONAL REQUIREMENTS AND QA REVIEWS ARE REQUIRED. (REMOVE THIS NOTE WHEN INSERTED INTO A DRAWING PACKAGE).

3	1-4-06	U	DY	ADDED KEYED NOTE 6 AND REVISED TITLE BLOCK.	RP	AY	CD	TO		
2	6-3-04	U		ADDED "F&T" TO MOISTURE SEPARATOR TRAP.	RP	RF	JM	CO TO		
1	8-13-03	U		REVISED DETAIL. DWG NO. WAS ST6202.	RP	RF	JM	GG TO		
NO	DATE	CLASS	REV	ADD	DESCRIPTION	OWN	DSGN	CHKD	SUB	APP

ENGINEERING STANDARDS PROGRAM									
ENGINEERING STANDARDS MANUAL								DRAWN R.PEARSON DESIGN R.FROST CHECKED C.DUPRE	
STEAM PRV STATION DETAIL PARALLEL									
BLDG X								TA-X	
SUBMITTED								APPROVED FOR RELEASE	
DISCIPLINE POC: GURINDER GREWAL								STANDARDS MANAGER: TOBIN ORUCH	
								SHEET 3 OF 4	
CLASSIFICATION: U PROJECT ID:								REVIEWER: LARRY BAYS DATE:	
DRAWING NO:								REV 3	
CHAPTER 6								ST-D3020-2	

STEAM PRV STATION DETAIL
SCALE: NONE

NOTES FOR DESIGNER: (DO NOT INCLUDE ON CONSTRUCTION DRAWINGS)

- 1. SEE SHEET 4.

C:\MARK_Eng\proj\Bldg\std\std.dwg [D:\D3020-2\std\std.dwg] 10/27/03 10:57:03 AM