



**KEYED NOTES:**

- 1 CONNECT STEAM TRAP CONDENSATE BRANCH LINE INTO TOP OF CONDENSATE MAIN OR AT 45° ANGLE FROM TOP OF MAIN.
- 2 PROVIDE 1/2" VALVE IN BOTTOM OF CONDENSATE LINE.

STEAM LINE SIZE	"D" (MIN)
UP TO 4"	LINE SIZE
6"	4"
8"	4"
10"	6"
12"	6"
14"	8"
16"	8"

**STEAM DRIP LEG DETAIL**  
SCALE: NONE

NOTES FOR DESIGNER: (DO NOT INCLUDE ON CONSTRUCTION DRAWINGS)

- 1. SEE SHEET 2.

DRAWING DEVELOPED FOR ML-3/ML-4 PROJECTS. FOR ML-1/ML-2, ADDITIONAL REQUIREMENTS AND QA REVIEWS ARE REQUIRED. (REMOVE THIS NOTE WHEN INSERTED INTO A DRAWING PACKAGE).

NO	DATE	CLASS REV	ADD	DESCRIPTION	OWN	DSGN	CHKD	SUB	APP
1	8-13-03	U		REVISED TO COMPLY WITH DRAFTING MANUAL, DRG NO. WAS 578203.	RP	RF	JM	GO	TO

**ENGINEERING STANDARDS PROGRAM**

<b>ENGINEERING STANDARDS MANUAL</b>		DRAWN	R.PEARSON
		DESIGN	A.BRIDGE
		CHECKED	G.GREWAL
STEAM DRIP LEG DETAIL ALONG PIPE RUN		DATE	8-28-99
BLDG X	TA-X		
SUBMITTED	APPROVED FOR RELEASE		
DISCIPLINE POC: GURINDER GREWAL	STANDARDS MANAGER: TOBIN ORUCH		
		PO Box 1663 Los Alamos, New Mexico 87545	
CLASSIFICATION: U	REVIEWER: LARRY BAYS	DATE:	
PROJECT ID	DRAWING NO	REV	
CHAPTER 6	ST-D3020-3	1	

C:\Users\Engineering\Breadboard\Draw\_Material [D:\D3020-3\Material\ST-D3020-3\Draw\_Area\_001\001.DWG @ 11:32:00 AM 08/28/99