



**STEAM DRIP PAN ELBOW DETAIL**  
SCALE: NONE

**NOTES FOR DESIGNER:** (DO NOT INCLUDE ON CONSTRUCTION DRAWINGS)

1. WHEN EDITING DETAIL TO SUIT PROJECT, ADD JOB SPECIFIC REQUIREMENTS AND DELETE ONLY THOSE PORTIONS THAT DO NOT APPLY. TO SEEK A VARIANCE FROM APPLICABLE REQUIREMENTS, CONTACT THE ESM MECHANICAL POC.
2. KEEP LENGTH OF DISCHARGE PIPING TO A MINIMUM.
3. PIPE DISCHARGE PIPING THROUGH ROOF. TERMINATE 10 FEET ABOVE ROOF TO PREVENT ANY POTENTIAL PERSONNEL BURN HAZARDS.
4. REFER TO THE FOLLOWING LANL STANDARDS FOR ADDITIONAL REQUIREMENTS:
  - A. MASTER SPECIFICATION 23 2217, STEAM AND CONDENSATE SPECIALTIES.
  - B. MASTER SPECIFICATION 23 2213, STEAM AND CONDENSATE HEATING PIPING.

DRAWING DEVELOPED FOR ML-3/ML-4 PROJECTS. FOR ML-1/ML-2, ADDITIONAL REQUIREMENTS AND QA REVIEWS ARE REQUIRED. (REMOVE THIS NOTE WHEN INSERTED INTO A DRAWING PACKAGE).

NO	DATE	CLASS	REV	ADD	DESCRIPTION	OWN	DSGN	CHKD	SUB	APP
1	8-13-03	U			REVISED TO COMPLY WITH DRAFTING MANUAL & REVISED DISCHARGE PIPING. DWG NO. WAS ST6204.	RP	RF	JM	GG	TO
<b>ENGINEERING STANDARDS PROGRAM</b>										
<b>ENGINEERING STANDARDS MANUAL</b>										DRAWN R.PEARSON
										DESIGN A.BRIDGE
STEAM DRIP PAN ELBOW DETAIL 1/2" - 1 1/2" SIZE										CHECKED G.GREWAL
										DATE 6-28-99
BLDG X					TA-X					
SUBMITTED					APPROVED FOR RELEASE					
DISCIPLINE POC: GURINDER GREWAL					STANDARDS MANAGER: TOBIN ORUCH					
SHEET										<b>2</b>
										<b>2</b>
CLASSIFICATION: U										REVIEWER: LARRY BAYS
PROJECT ID										DATE:
DRAWING NO										REV
<b>CHPATER 6</b>										<b>ST-D3020-4</b>
										<b>1</b>