

TABLE OF CONTENTS

1.0 Purpose and Scope 2

2.0 Chapter Hierarchy 2

3.0 Acronyms /Definitions 3

4.0 Responsibilities and Duties 3

5.0 Process 7

6.0 Appendices 8

Appendix A Special Inspection and Testing Summary – Sample

Appendix B Test and Inspection Plan Template

Appendix C Nonconformance Report Example

Appendix D IBC Inspection Daily Report -- Sample

Appendix E IBC Inspection Final Report -- Sample

Appendix F Job Task List for Inspectors (Guidance)

Appendix G Structural Observation Report (Sample)

RECORD OF REVISIONS

Rev	Date	Description	POC	RM
0	10/27/06	Initial issue.	Tobin Oruch, <i>CENG-OFF</i>	Kirk Christensen, <i>CENG-OFF</i>
1	6/26/07	New App G for structural observation. ML level, reordering, other minor changes. App B, E reformatting.	Tobin Oruch, <i>CENG-OFF</i>	Kirk Christensen, <i>CENG-OFF</i>
2	7/21/08	Clarified structural observation, AE submittal approval, inspection basis. Minor changes to App B and G.	Tobin Oruch, <i>CENG-OFF</i>	Kirk Christensen, <i>CENG-OFF</i>

PLEASE CONTACT THE ESM IBC PROGRAM POC
for upkeep, interpretation, and variance issues


Section IBC-IP	<u>IBC Program Committee</u>
-----------------------	--

LANL Eng Standards including this one: <http://engstandards.lanl.gov>

1.0 Purpose and Scope

- A. The purpose of this section is to establish the process, the authority, and duties and reporting functions of IBC Inspections at LANL. It shall be used in conjunction with Section IBC-GEN of this chapter.
- B. The scope of this section applies to design professionals, constructing subcontractors, and IBC inspectors as they relate to the scope of the IBC, the LANL Program, and other duties assigned by the LBO or in support of activities addressed in the IBC (or IEBC) or this section. IBC Inspectors are those qualified by the LBO either directly or through the LBO's approval of an inspection agency.
- C. This IBC inspection process is specifically for IBC and IEBC work. Additional requirements are expected for ML-1 and ML-2 (nuclear) and ML-3 work; such higher-quality processes cannot reduce IBC levels of quality or inspections unless specifically authorized by the LBO in writing.
- D. LANL personnel: See P [330-8](#), *Inspection for Test and Acceptance*, for potential additional requirements.

2.0 Chapter Hierarchy



3.0 Acronyms /Definitions

ACI	American Concrete Institute
ADPMGT	Project Management Services Directorate (LANL)
ASNT	American Society for Nondestructive Testing
ASTM	ASTM International (formerly American Society for Testing and Materials)
AWS/ACWI	American Welding Society/Associate Certified Welding Inspector
AWS/CWI	American Welding Society/Certified Welding Inspector
DPIRC	Design Professional in Responsible Charge
IAS	International Accreditation Service (subsidiary of ICC)
IBC	International Building Code published by ICC
IBC Inspector	Same as inspector (terms used interchangeably in this Chapter)
ICC	International Code Council
ICC-ER/ESR	International Code Council-Evaluation Report/ Evaluation Service Report
IEBC	International Existing Building Code published by ICC
LBO	LANL Building Official
project	Term for any type of work/job/task/ that is performed under the purview of IBC regardless of funding source or facility arrangement.

4.0 Responsibilities and Duties

A. LANL PROJECT OWNER (NORMALLY PM OR FACILITY MANAGEMENT) DUTIES AND RESPONSIBILITIES

1. The project owner is responsible for funding IBC inspection services. The IBC inspector or inspection agency shall not be in the employ of a non-LANL constructing subcontractor or material supplier.¹

B. PRIME SUBCONTRACTOR DUTIES AND RESPONSIBILITIES

These are addressed in LANL Master Specification Section [01 4000](#), Quality Requirements.

The prime Subcontractor must assure that necessary requirements related to the project including hold points, design documents, and IBC requirements are passed-down to subtier subcontractors and suppliers.

C. DESIGN PROFESSIONAL IN RESPONSIBLE CHARGE DUTIES AND RESPONSIBILITIES

1. The DPIRC has many duties and responsibilities related to inspection, including the following:
 - Prepare initial Test and Inspection Plan. The DPIRC shall list the special inspections (per IBC Ch 17) to include structural element fabrication observation when required by the Code, whether inspections are continuous or

¹ IBC 2006 Section 109.1

periodic, and the details of such inspection (see IBC Section 106.3.4). The DPIRC shall further include additional, critical items for which inspection is required, and hold and witness points (shop or field).

- i. Appendix B is a partial template for special inspection tasks and may serve as an acceptable format and starting point for preparation of the inspection program that can be easily reviewed by the LBO designees. Note: listing the specific agency performing special inspection is not required since LANL will provide these services.
 - ii. The DPIRC shall detail structural observations (performed by structural engineer of record not in same company as Subcontractor; see App G Structural Observation Report), and any required seismic testing. LBO may authorize observations by those other than the structural DPIRC.
- Submit approved plans in native electronic file to allow Subcontractor to add additional required and planned inspections and integrate with scheduling data. LANL design reviewers and inspectors may also require additional inspections and hold points to be added. Special inspection plan may be maintained separately from more routine inspection plan with written permission of LANL Chief Inspector.

2. The DPIRC shall also:

- When DPIRC is contracted by LANL to perform special inspection duties (this is rare), submit inspection agencies to the LBO for approval.
- *Respond to field discrepancies.* The DPIRC shall respond to non-conformance reports (NCRs) that are dispositioned as Use-As-Is or Repair (not required when Rework or Scrap/Reject). See also ESM Ch 1 Section Z10 subsection on Clarifications, NCRs, etc.
- Review shop and fabrication drawings and submit revisions to approved design documents: The DPIRC shall acknowledge and approve (with a stamp) shop/fabrication drawings. The DPIRC shall submit to the LBO-designated design reviewers for written approval of any deviations to the approved plans, drawings, or specifications and shall re-submit revised plans, drawings, and specifications that may be required due to the shop drawings, etc. Upon approval, send copy to the LANL Construction Inspection group.

D. IBC INSPECTORS AND/OR INSPECTION DUTIES

1. **General requirements.** IBC inspectors shall review approved plans and specifications for inspection requirements. IBC inspectors will comply with the inspection requirements of LANL.
2. **Signify presence at jobsite.** IBC inspectors shall notify subcontractor of their presence and responsibilities at the jobsite location. If required by the LBO they shall sign in on the appropriate form posted by the subcontractor.
3. **Observe assigned work.** IBC inspectors shall inspect all work in the inspection program for conformance with the LBO-approved drawings and specifications, applicable provisions of IBC Section 1704 on special inspection, and applicable workmanship provisions of the IBC; approved shop drawings may be used only as an aid to inspection. Inspections include special inspections in the structural fabricator's shop when required and other inspection identified in the

- inspection/QA plan for the work. Example inspection plans and records are included as Appendices.
4. For continuous inspection, the inspector shall be onsite at all times observing the work requiring inspection designated as “continuous.” Periodic inspection is intended to mean that the inspector at periodic times inspects all work performed but is not required to “witness” the work being performed.
 5. Notify the LANL Chief Inspector immediately in cases where project conditions or personnel do not provide adequate notice for hold or witness points, inhibit the inspector’s ability to inspect or any conditions that present themselves that would prevent adequate inspection. An example could be related to funding where non-conformances cause additional work and inspection costs but the project does not want to increase funding to cover additional costs for inspection.
 6. Welding inspection subject to IBC Chapter 17 shall only be performed by Certified Welding Inspectors that have been approved by the LANL Welding Program Administrator (WPA)/Chief Inspector for IBC welding on behalf of the LBO.
 - A. LANL personnel pre-approved for such inspection are listed on the LANL Welding Program website (ESM Chapter 13) in the Approved Inspector listing on the website and as a reference under General Welding Standard GWS 1-03 (e.g., they have a “Yes” in IBC/IEBC column of table).
<http://engstandards.lanl.gov/engrman/13weld/html/13-vol1.htm>
 - B. Non-LANL CWIs shall be submitted for approval to the LANL WPA via the Project Manager.
 7. **Report nonconforming items.** IBC inspectors shall bring all nonconforming items to the immediate attention of the subcontractor. If any such item(s) is not resolved in a timely manner or is about to be incorporated into the work, the LBO and design professional in responsible charge (DPRIC) should be notified immediately and the item noted in the IBC inspector's written report (see IBC Section 1704.1). An example of a nonconformance report is included as Appendix C. The IBC inspector shall write a separate report regarding noted discrepancies which should contain, as a minimum, the following information about each nonconforming item:
 - A. Description and exact location
 - B. Reference to applicable design detail approved
 - C. Name and title of each individual notified and method of notification
 - D. Resolution or corrective action taken
 8. **Provide timely reports.** The IBC inspector shall complete written inspection reports for each inspection visit and provide the reports on a timely basis as determined by the LBO. The IBC inspector or inspection agency shall furnish these reports directly to the LANL Chief Inspector, DPIRC, and others as designated by the project manager (see IBC Section 1704.1.2). These reports should be generated on a daily basis and may be submitted weekly at the option of the Chief Inspector. Examples of daily report forms are included in the Appendices. In these reports, IBC inspectors should:
 - Describe inspections and tests made with applicable locations
 - Indicate how nonconforming items were resolved
 - List unresolved items, parties notified, and time and method of notification

- Itemize changes authorized by DPIRC if not included in nonconforming items
 - Stop work notices, NCRs, or other documentation vehicles that provide information regarding the quality of the IBC-related work.
9. **Submit final report.** IBC inspectors or inspection agencies shall submit a final signed report to the LBO, Chief Inspector, and DPIRC stating that all items requiring IBC inspection and testing were fulfilled and reported and, to the best of their knowledge in conformance with the approved drawings, specifications and the applicable provisions of the IBC (see IBC Section 1704.1.2). Items not in conformance, unresolved items or any discrepancies in inspection coverage, missed inspections, periodic inspection when continuous was required, etc. should be specifically itemized in this report. An example of a final report form is included as Appendix E.
10. The IBC inspector shall notify the LBO (regardless of whether the inspector reports directly to the LBO, the inspection agencies, or other entity on site) immediately when conditions on a project, job or other work under IBC causes the inspector to be unable to perform their duties. This can be due to lack of notification of hold or witness points, lack of funding, reduced funding, or any conditions that impacts the inspectors' independence.

E. LBO DUTIES AND RESPONSIBILITIES

1. The specific duties and responsibilities of the LBO relating to inspection include the following (generally delegated downward):
- **Review submittal documents for compliance with special inspection requirements.** The LBO is charged with the authority to review the plans, specifications, inspection program, and other submittal documents for compliance with Code requirements.²
 - **Approve inspection program.** The LBO is responsible for approving the inspection program submitted by the DPIRC when acceptable (see IBC Section 1704.1) and may require a preconstruction conference to review the program with all applicable members of the construction team.
 - **Approve inspectors/inspection agencies.** The LBO is responsible for determining competence of inspectors for the types of work they will be inspecting (see IBC Section 1704). See Appendix F to this section, Job Task List for Special Inspectors; also, qualification guidance for inspectors is contained in ESM Ch 16, Section IBC-TIA, Attachment B.
 - **Monitor special inspection activities.** The LBO should monitor the inspection activities at the jobsite to assure that qualified inspectors are performing their duties when work requiring inspection is in progress.

² IBC 2006 Sections 104.2, 106.3 and 106.3 through 106.5

- **Review inspection reports.** The LBO receives and reviews inspection progress reports and final reports for conformance with the approved plans, specifications and workmanship provisions of the Code.³
- **Approval of NCR dispositions.** This is delegated to the project's LANL Design Authority Representative.
- **Perform final inspection.** The LBO should not release the structure for occupancy or use until the final inspection report has been completed (see Section IBC-GEN).

5.0 Process

- A. The DPIRC submit the design package including the Test and Inspection Plan to the LBO for review and approval.
- B. The LBO or his designees review and approve the design media and the QA plan and return it to the project for implementation or they return it with comments that need to be resolved.
- C. If there are comments to be resolved the project cannot proceed with construction or structural fabrication activities without the LBO concurrence.
- D. Once the package is fully approved by the LBO and returned to the project/job the project team can begin the appropriate phases of the work.
- E. The project assures that the inspectors have enough funding to fully comply with the Inspection Plan.
- F. Seismic structural member fabrication work is performed by an approved fabricator or is accomplished with one or more special inspectors in the shop when required by IBC Ch. 17. Designation as an approved fabricator is obtained from the LBO (see ESM Chapter 16 Section IBC-FAB). Such structural work requires a Certificate of Conformance (FAB Att B).
- G. Work progresses and the inspector(s) perform their inspections, fill out the reports, and notify the LBO if non-conformances occur.
- H. Inspection will be performed against design approved by both AE and LANL, and to design specifications and drawings (as opposed to approved shop drawings) when they are available and sufficiently detailed.
- I. Structural Engineer of Record performs required observations and completes report (IBC-IP App G).
- J. Upon completion of the work, the project manager notifies the LBO who performs a final inspection review to his/her satisfaction prior to granting an occupancy authorization.

³ IBC 2006 Section 1704.1.2

- K. All inspection records and any others required by IBC or IEBC are submitted to the LBO's Chief Inspector.

6.0 Appendices

- A. Special Inspection and Testing Summary – Sample
- B. Test and Inspection Plan Template*
- C. Nonconformance Report – Sample
- D. IBC Inspection Daily Report – Sample*
- E. IBC Inspection Final Report – Sample*
- F. Job Task List for Inspectors (Guidance)
- G. Structural Observation Report (Sample)*

* Indicates record document