

2015 International Fire Code Errata

(Portions of text and tables not shown are unaffected by the errata)

Second PRINTING (Updated June 3rd, 2015)

CHAPTER 5 FIRE SERVICE FEATURES

508.1.6 Required features. The *fire command center* shall comply with NFPA 72 and shall contain the following features:

1-16 (no change)

17. Elevator fire recall switch in accordance with ASME A17.1/[CSA B44](#).

18. (no change)

2015 International Fire Code Errata

(Portions of text and tables not shown are unaffected by the errata)

Second PRINTING (Updated June 3rd, 2015)

CHAPTER 6 BUILDING SERVICES AND SYSTEMS

607.1 Emergency operation. Existing elevators with a travel distance of 25 feet (7620 mm) or more shall comply with the requirements in Chapter 11. New elevators shall be provided with Phase I emergency recall operation and Phase II emergency in-car operation in accordance with ASME A17.1 [/CSA B44](#).

2015 International Fire Code Errata

(Portions of text and tables not shown are unaffected by the errata)

FIRST PRINTING (Updated October 30, 2014)

CHAPTER 6 BUILDING SERVICES AND SYSTEMS

607.6 Water protection of hoistway enclosures. Methods to prevent water from infiltrating into a hoistway enclosure required by Section ~~3007.4~~ 3007.3 and Section ~~3008.4~~ 3008.3 of the *International Building Code* shall be maintained.

2015 International Fire Code Errata

(Portions of text and tables not shown are unaffected by the errata)

FIRST PRINTING (Updated July 13, 2015)

CHAPTER 8

INTERIOR FINISH, DECORATIVE MATERIALS AND FURNISHINGS

TABLE 803.3

INTERIOR WALL AND CEILING FINISH REQUIREMENTS BY OCCUPANCY^k

GROUP	SPRINKLERED ^l			NONSPRINKLERED		
	Interior exit stairways, interior exit and ramps and exit passageways ^{a, b}	Corridors and enclosure for exit access stairways and exit-access ramps	Rooms and enclosed spaces ^c	Interior exit stairways, interior exit and ramps and exit passageways ^{a, b}	Corridors and enclosure for exit access stairways and exit-access ramps	Rooms and enclosed spaces ^c

Note: Remainder of table remain unchanged

805.3.2.2.2 Mass loss test. Newly introduced mattresses shall have a mass loss not exceeding 15 percent of the initial mass of the mattress where tested in accordance with the test in ~~Annex A~~ Annex A3 of ASTM F 1085.

807.3 Combustible decorative materials. In other than Group I-3, curtains, draperies, fabric hangings and other similar combustible decorative materials suspended from walls or ceilings shall comply with Section 807.4 and shall not exceed 10 percent of the specific wall or ceiling area to which they are attached.

Fixed or movable walls and partitions, paneling, wall pads and crash pads applied structurally or for decoration, acoustical correction, surface insulation or other purposes shall be considered *interior finish*, shall comply with Section 803 and shall not be considered *decorative materials* or furnishings.

Exceptions:

1. In auditoriums in Group A, the permissible amount of curtains, draperies, fabric hangings and other similar combustible decorative material suspended from walls or ceilings shall not exceed 75 percent of the aggregate wall area where the building is equipped throughout with an *approved automatic sprinkler system* in accordance with Section 903.3.1.1.1, and where the material is installed in accordance with Section ~~803.11~~ 803.13 of the *International Building Code*.
2. and 3. (No change)

2015 International Fire Code Errata

(Portions of text and tables not shown are unaffected by the errata)

FIRST PRINTING (Updated October 30, 2014)

CHAPTER 8 INTERIOR FINISH, DECORATIVE MATERIALS AND FURNISHINGS

**TABLE 803.3
INTERIOR WALL AND CEILING FINISH REQUIREMENTS BY OCCUPANCY^k**

GROUP	SPRINKLERED ^l			NONSPRINKLERED		
	Interior exit stairways, interior exit and ramps and exit passageways ^{a, b}	Corridors and enclosure for exit access stairways and exit-access ramps	Rooms and enclosed spaces ^c	Interior exit stairways, interior-exit and ramps and exit passageways ^{a, b}	Corridors and enclosure for exit access stairways and exit-access ramps	Rooms and enclosed spaces ^c
A-1 & A-2	B	B	C	A	A ^d	B ^e
A-3 ^f , A-4, A-5	B	B	C	A	A ^d	C
B, E, M, R-1, R-4	B	C	C	A	B	C
F	C	C	C	B	C	C
H	B	B	C ^g	A	A	B
I-1	B	C	C	A	B	B
I-2	B	B	B ^{h, i}	A	A	B
I-3	A	A ^j	C	A	A	B
I-4	B	B	B ^{h, i}	A	A	B
R-2	C	C	C	B	B	C
R-3	C	C	C	C	C	C
S	C	C	C	B	B	C
U	No Restrictions			No Restrictions		

For SI: 1 inch = 25.4 mm, 1 square foot = 0.0929 m².

- a. Class C interior finish materials shall be allowed for wainscoting or paneling of not more than 1,000 square feet of applied surface area in the grade lobby where applied directly to a noncombustible base or over furring strips applied to a noncombustible base and fireblocked as required by Section 803.11 of the *International Building Code*.
- b. In exit enclosures of buildings less than three stories in height of other than Group I-3, Class B interior finish for nonsprinklered buildings and Class C for sprinklered buildings shall be permitted.
- c. Requirements for rooms and enclosed spaces shall be based upon spaces enclosed by partitions. Where a fire-resistance rating is required for structural elements, the enclosing partitions shall extend from the floor to the ceiling. Partitions that do not comply with this shall be considered as enclosing spaces and the rooms or spaces on both sides shall be considered as one. In determining the applicable requirements for rooms and enclosed spaces, the specific occupancy thereof shall be the governing factor regardless of the group classification of the building or structure.
- d. Lobby areas in Group A-1, A-2 and A-3 occupancies shall not be less than Class B materials.
- e. Class C interior finish materials shall be allowed in Group A occupancies with an occupant load of 300 persons or less.
- f. In places of religious worship, wood used for ornamental purposes, trusses, paneling or chancel furnishing shall be allowed.
- g. Class B material is required where the building exceeds two stories.
- h. Class C interior finish materials shall be allowed in administrative spaces.
- i. Class C interior finish materials shall be allowed in rooms with a capacity of four persons or less.
- j. Class B materials shall be allowed as wainscoting extending not more than 48 inches above the finished floor in corridors.
- k. Finish materials as provided for in other sections of this code.
- l. Applies when the vertical exits, exit passageways, corridors or rooms and spaces are protected by an approved automatic sprinkler system installed in accordance with Section 903.3.1.1 or 903.3.1.2.

807.3 Combustible decorative materials. In other than Group I-3, curtains, draperies, fabric hangings and other similar combustible decorative materials suspended from walls or ceilings shall comply with Section 807.4 and shall not exceed 10 percent of the specific wall or ceiling area to which they are attached.

2015 International Fire Code Errata

(Portions of text and tables not shown are unaffected by the errata)

Fixed or movable walls and partitions, paneling, wall pads and crash pads applied structurally or for decoration, acoustical correction, surface insulation or other purposes shall be considered *interior finish*, shall comply with Section 803 and shall not be considered *decorative materials* or furnishings.

Exceptions:

1. In auditoriums in Group A, the permissible amount of curtains, draperies, fabric hangings and other similar combustible decorative material suspended from walls or ceilings shall not exceed 75 percent of the aggregate wall area where the building is equipped throughout with an *approved automatic sprinkler system* in accordance with Section 903.3.1.1, and where the material is installed in accordance with Section ~~803.14~~ **803.13** of the *International Building Code*.
2. In Group R-2 dormitories, within sleeping units and dwelling units, the permissible amount of curtains, draperies, fabric hangings and other similar decorative materials suspended from walls or ceiling shall not exceed 50 percent of the aggregate wall areas where the building is equipped throughout with an *approved automatic sprinkler system* installed in accordance with Section 903.3.1. (*relocated and revised from Section 807.1, exception 1*)
- ~~2.3.~~ In Group B and M occupancies, the amount of combustible fabric partitions suspended from the ceiling and not supported by the floor shall comply with Section 807.4 and shall not be limited.

2015 International Fire Code Errata

(Portions of text and tables not shown are unaffected by the errata)

SECOND PRINTING (Updated June 3rd, 2015)

CHAPTER 9 FIRE PROTECTION SYSTEMS

907.3.3 Elevator emergency operation. Automatic fire detectors installed for elevator emergency operation shall be installed in accordance with the provisions of ASME A17.1/[CSA B44](#) and NFPA 72.

2015 International Fire Code Errata

(Portions of text and tables not shown are unaffected by the errata)

FIRST PRINTING (Updated October 30, 2014)

CHAPTER 9 FIRE PROTECTION SYSTEMS

903.2.11.1 Stories without openings. An *automatic sprinkler system* shall be installed throughout all stories, including *basements*, of all buildings where the floor area exceeds 1,500 square feet (139.4 m²) and where there is not provided not fewer than one of the following types of *exterior wall* openings:

1. Openings below grade that lead directly to ground level by an exterior *stairway* complying with Section ~~4009~~ 1011 or an outside ramp complying with Section ~~4040-1012~~. Openings shall be located in each 50 linear feet (15 240 mm), or fraction thereof, of *exterior wall* in the story on at least one side. The required openings shall be distributed such that the lineal distance between adjacent openings does not exceed 50 feet (15 240 mm).
2. (No change)

904.3.2 Actuation. Automatic fire-extinguishing systems shall be automatically actuated and provided with a manual means of actuation in accordance with Section ~~904.11.1~~ 904.12.1. Where more than one hazard could be simultaneously involved in fire due to their proximity, all hazards shall be protected by a single system designed to protect all hazards that could become involved.

Exception: Multiple systems shall be permitted to be installed if they are designed to operate simultaneously.

909.5 Smoke barrier construction. *Smoke barriers* required for passive smoke control and a smoke control system using the pressurization method shall comply with Section 709 of the *International Building Code*. ~~Smoke barriers shall be constructed and sealed to limit leakage areas exclusive of protected openings.~~ The maximum allowable leakage area shall be the aggregate area calculated using the following leakage area ratios: (*Remainder of section unchanged.*)

914.3.1.1.1 Riser location. Sprinkler risers shall be placed in interior exit stairways and ramps that are remotely located in accordance with Section 1007 ~~4045.2~~.

2015 International Fire Code Errata

(Portions of text and tables not shown are unaffected by the errata)

SECOND PRINTING (Updated June 3rd, 2015)

CHAPTER 10 MEANS OF EGRESS

[BE] 1009.4 Elevators. In order to be considered part of an *accessible means of egress*, an elevator shall comply with the emergency operation and signaling device requirements of Section 2.27 of ASME A17.1/[CSA B44](#). Standby power shall be provided in accordance with Section 604 of this code and Section 3003 of the *International Building Code*. The elevator shall be accessed from an *area of refuge* complying with Section 1009.6.

2015 International Fire Code Errata

(Portions of text and tables not shown are unaffected by the errata)

FIRST PRINTING (Updated October 30, 2014)

CHAPTER 10 MEANS OF EGRESS

(Remove ** in margin)

1006.3 Egress from stories or occupied roofs. The means of egress system serving any story or occupied roof shall be provided with the number of exits or access to exits based on the aggregate occupant load served in accordance with this section. The path of egress travel to an *exit* shall not pass through more than one adjacent story.

~~Each story above the second story of a building shall have a minimum of one interior or exterior exit stairway, or interior or exterior exit ramp. Where not less than three exits or access to exits are required, not less than 50 percent of the required exits shall be interior or exterior exit stairways or ramps.~~

Exceptions:

- ~~1. Interior exit stairways and interior exit ramps are not required in open parking garages where the means of egress serves only the open parking garage.~~
- ~~2. Interior exit stairways and interior exit ramps are not required in outdoor facilities where all portions of the means of egress are essentially open to the outside.~~

1006.3.1 Egress based on occupant load. Each story and occupied roof shall have the minimum number of independent exits, or access to exits, as specified in Table 1006.3.1. A single exit or access to a single exit shall be permitted in accordance with Section 1006.3.2. The required number of exits, or *exit access stairways* or *ramps* providing access to exits, from any story or occupied roof shall be maintained until arrival at the exit discharge or a *public way*.

(Remove ** in margin)

~~**1006.3.2.2 Basements.** A basement provided with one exit shall not be located more than one story below grade plane.~~

1010.1.4.1 Revolving doors. Revolving doors shall comply with the following:

1 to 4 (no change)

5. An emergency stop switch shall be provided near each entry point of a power or automatic operated revolving door doors within 48 inches (1220 mm) of the door and between 24 inches (610 mm) and 48 inches (1220 mm) above the floor. The activation area of the emergency stop switch button shall be not less than 1 inch (25 mm) in diameter and shall be red.

6 and 7 (no change)

1010.1.4.3 Special purpose horizontal sliding, accordion or folding doors. In other than Group H occupancies, special purpose horizontal sliding, accordion or folding door assemblies permitted to be a component of a means of egress in accordance with Exception 6 to Section 1010.1.2 shall comply with all of the following criteria:

1. And 2. (no change)

3. The force required to operate the door shall not exceed 30 pounds (133 N) to set the door in motion and 15 pounds (67 N) to close or open the door or open it to the minimum required width.

2. through 7. (no change)

1011.14.1 Handrails of alternating tread devices. Handrails shall be provided on both sides of alternating tread devices and shall comply with Section ~~4024~~ 1014.

1015.1 General. Guards shall comply with the provisions of Sections 1015.2 through ~~4045.6~~ 1015.7. Operable windows with sills located more than 72 inches (1.83 m) above finished grade or other surface below shall comply with Section ~~4045.7~~ 1015.8.

1029.9.1 Minimum aisle width. The minimum clear width for aisles shall be as shown:

1. Forty-eight inches (1219 mm) for stepped aisles having seating on each side.

Exception: Thirty-six inches (914 mm) where the stepped aisles serves less than 50 seats.

2015 International Fire Code Errata

(Portions of text and tables not shown are unaffected by the errata)

2. Thirty-six inches (914 mm) for stepped aisles having seating on only one side.

Exception: Twenty-three inches (584 mm) between ~~an aisle stair~~ a stepped aisles handrail and seating where an stepped aisles does not serve more than five rows on one side.

3. Twenty-three inches (584 mm) between a stepped aisles handrail or guard and seating where the stepped aisles is subdivided by a mid-aisle handrail.
4. Forty-two inches (1067 mm) for level or ramped aisles having seating on both sides.

Exceptions:

1. Thirty-six inches (914 mm) where the aisle serves less than 50 seats.
 2. Thirty inches (762 mm) where the aisle does not serve more than 14 seats.
 - 3.
5. Thirty-six inches (914 mm) for level or ramped aisles having seating on only one side.

Exception: For other than ramped aisles that serve as part of an accessible route, thirty inches (762 mm) where the ramped aisle does not serve more than 14 seats.

1029.9.7 Stairways connecting to stepped aisles. A stairway that connects a stepped aisle to a cross aisle or concourse shall be permitted to comply with the assembly aisle walking surface requirements of Section ~~1029.12~~ 1029.13. Transitions between stairways and stepped aisles shall comply with Section 1029.10.

1029.9.8 Stairways connecting to vomitories. A stairway that connects a vomitory to a cross aisle or concourse shall be permitted to comply with the assembly aisle walking surface requirements of Section ~~1029.12~~ 1029.13. Transitions between stairways and stepped aisles shall comply with Section 1029.10.

1029.10.1 Transitions and stairways that maintain stepped aisle riser and tread dimensions. Stepped aisles, transitions and stairways that maintain riser and tread dimensions shall comply with Section ~~1029.12~~ 1029.13 as one exit access component.

1029.13.1.3 Edge protection. Ramped aisles shall have edge protection in accordance with Section 1012.10 and 1012.10.1 ~~4012-14~~.

Exception: In assembly spaces with fixed seating, edge protection is not required on the sides of ramped aisles where the ramped aisles provide access to the adjacent seating and aisle accessways.

1029.14 Seat stability. In a building, room or space used for assembly purposes, the seats shall be securely fastened to the floor.

Exceptions:

1. *(no change)*
2. In a building, room or space used for assembly purposes or portions thereof with seating at tables and without ramped or tiered floors for seating, the seats shall not be required to be fastened to the floor.
3. through 6. *(no change)*

2015 International Fire Code Errata

(Portions of text and tables not shown are unaffected by the errata)

SECOND PRINTING (Updated July 24, 2015)

CHAPTER 11

CONSTRUCTION REQUIREMENTS FOR EXISTING BUILDINGS

1105.6 Smoke compartments. Smoke compartments shall be provided in existing Group I-2 Condition 2, in accordance with Sections 1105.6.1 through 1105.6.6 ~~1105.6.4~~.

1105.9 Group I-2 automatic fire alarm system. An automatic fire alarm system shall be installed in existing Group I- 2 occupancies in accordance with Section 907.2.6.2.

Exception: Manual fire alarm boxes in patient sleeping areas shall not be required at *exits* if located at all nurses' control stations or other constantly attended staff locations, provided such stations are visible and continuously accessible and that travel distances required in Section ~~907.5.2.4~~ 907.4.2.1 are not exceeded.

2015 International Fire Code Errata

(Portions of text and tables not shown are unaffected by the errata)

FIRST PRINTING (Updated October 30, 2014)

CHAPTER 11 CONSTRUCTION REQUIREMENTS FOR EXISTING BUILDINGS

~~1103.5.1 Group A-2. An automatic sprinkler system shall be installed in accordance with Section 903.3.1.1 throughout existing buildings or portions thereof used as Group A-2 occupancies with an occupant load of 300 or more.~~

1105.7 Group I-2 care suites. Care suites in existing Group I-2 Condition 2 occupancies shall comply with Sections ~~407.4.3~~ 407.4.4 through ~~407.4.3.6.2~~ 407.4.4.6.2 of the *International Building Code*.

2015 International Fire Code Errata

(Portions of text and tables not shown are unaffected by the errata)

FIRST PRINTING (Updated October 30, 2014)

CHAPTER 23 MOTOR FUEL-DISPENSING FACILITIES AND REPAIR GARAGES

2306.8.3 Change of system contents. Fuel-dispensing systems subject to change in contents from gasoline to alcohol-blended fuels shall be subject to *fire code official* review and approval prior to commencing dispensing operations.

~~2306.8.3~~ 2306.8.4 Facility identification. Facilities dispensing alcohol-blended fuels shall be identified by an *Approved* means.

~~2306.8.4~~ 2306.8.5 Marking. Dispensers shall be marked in an *approved* manner to identify the types of alcohol-blended fuels to be dispensed.

~~2306.8.5~~ 2306.8.6 Maintenance and inspection. Equipment shall be maintained and inspected in accordance with Section 2305.2.

2015 International Fire Code Errata

(Portions of text and tables not shown are unaffected by the errata)

FIRST PRINTING (Updated October 30, 2014)

CHAPTER 27 SEMICONDUCTOR FABRICATION FACILITIES

TABLE 2705.2.2

Maximum quantities of HPM at a workstation

For SI: 1 pound = 0.454 kg, 1 gallon = 3.785 L.

- a. Maximum allowable quantities shall be increased 100 percent for closed system operations. **Where** Note b also applies, the increase for both notes shall be allowed.
- b. Quantities shall be allowed to be increased 100 percent **where** workstations are internally protected with an approved automatic fire extinguishing or suppression system complying with Chapter 9. **Where** Note ~~b~~ a also applies, the increase for both notes shall be allowed. **Where** Note e also applies, the maximum increase allowed for both Notes b and e shall not exceed 100 percent.
- c. Allowed only in workstations that are internally protected with an approved automatic fire-extinguishing or fire protection system complying with Chapter 9 and compatible with the reactivity of materials in use at the workstation.
- d. The quantity limits apply only to materials classified as HPM.
- e. Quantities shall be allowed to be increased 100 percent for nonflammable, noncombustible corrosive liquids **where** the materials of construction for workstations are listed or approved for use without internal fireextinguishing or suppression system protection. **Where** Note b also applies, the maximum increase allowed for both Notes b and e shall not exceed 100 percent.
- f. A maximum quantity of 5.3 gallons of liquids and 44 pounds of total liquids and solids shall be allowed at a workstation **where** conditions are in accordance with ~~Section 2705.2.3.5~~ Section 2705.2.3.4.

2015 International Fire Code Errata

(Portions of text and tables not shown are unaffected by the errata)

FIRST PRINTING (Updated October 30, 2014)

CHAPTER 33 FIRESAFETY DURING CONSTRUCTION AND DEMOLITION

[BS BE] 3311.1 Stairways required. Where a building has been constructed to a *building height* of 50 feet (15 240 mm) or four stories, or where an existing building exceeding 50 feet (15 240 mm) in *building height* is altered, not less than one temporary lighted *stairway* shall be provided unless one or more of the permanent *stairways* are erected as the construction progresses.

2015 International Fire Code Errata

(Portions of text and tables not shown are unaffected by the errata)

FIRST PRINTING (Updated October 30, 2014)

CHAPTER 37 COMBUSTIBLE FIBERS

3703.7.2 Open flames. Open flames and high-temperature devices shall not be used in a manner that creates a hazardous condition ~~and shall be listed for use with the materials stored or used~~. High-temperature devices and those devices utilizing an open flame shall be listed for use with the materials stored or used.

2015 International Fire Code Errata

(Portions of text and tables not shown are unaffected by the errata)

Second PRINTING (Updated June 3rd, 2015)

CHAPTER 50 HAZARDOUS MATERIALS – GENERAL PROVISIONS

Table 5003.1.1(1) First column “Combustible fibers” the footnote should be “q”

Combustible fiber^{q9}

2015 International Fire Code Errata

(Portions of text and tables not shown are unaffected by the errata)

FIRST PRINTING (Updated October 30, 2014)

CHAPTER 57 FLAMMABLE AND COMBUSTIBLE LIQUIDS

5704.2.7.5.8 Overfill prevention. An *approved* means or method in accordance with Section ~~5704.2.9.7.6~~ 5704.2.9.7.5 shall be provided to prevent the overfill of all Class I, II and IIIA liquid storage tanks. Storage tanks in refineries, bulk plants or terminals regulated by Section 5706.4 or 5706.7 shall have overfill protection in accordance with API 2350.

An *approved* means or method in accordance with Section ~~5704.2.9.7.6~~ 5704.2.9.7.5 shall be provided to prevent the overfilling of Class IIIB liquid storage tanks connected to fuel-burning equipment inside buildings.

Exception: Outside above-ground tanks with a capacity of 1,320 gallons (5000 L) or less.

5704.2.9.5.2 Fill pipe connections. Fill pipe connections for tanks storing Class I, II and IIIA liquids and Class IIIB liquids connected to fuel-burning equipment shall be in accordance with Section ~~5704.2.9.7.7~~ 5704.2.9.7.6.

2015 International Fire Code Errata

(Portions of text and tables not shown are unaffected by the errata)

FIRST PRINTING (Updated October 30, 2014)

CHAPTER 61 LIQUEFIED PETROLEUM GASES

6104.3.2 Special hazards. LP-gas containers shall be located with respect to special hazards including, but not limited to, above-ground flammable or *combustible liquid* tanks, oxygen or gaseous hydrogen containers, flooding or electric power lines as specified in Section ~~6.4.5~~ 6.4.4 of NFPA 58.

2015 International Fire Code Errata

(Portions of text and tables not shown are unaffected by the errata)

FIRST PRINTING (Updated October 30, 2014)

CHAPTER 63

OXIDIZERS, OXIDIZING GASES AND OXIDIZING CRYOGENIC FLUIDS

6303.2 Class 1 oxidizer storage configuration. The storage configuration of Class ~~1~~1 liquid and solid oxidizers shall be as set forth in Table 6303.2.

2015 International Fire Code Errata

(Portions of text and tables not shown are unaffected by the errata)

FIRST PRINTING (Updated October 30, 2014)

APPENDIX K CONSTRUCTION REQUIREMENTS FOR EXISTING AMBULATORY CARE FACILITIES

K104.1 Size of doors. The minimum width of each door opening shall be sufficient for the *occupant load* thereof and shall provide a clear width of not less than 28 inches (711 mm). Where this section requires a minimum clear width of 28 inches (711 mm) and a door opening includes two door leaves without a mullion, one leaf shall provide a clear opening width of 28 inches (711 mm). In ambulatory care facilities, doors serving as *means of egress* from patient treatment rooms shall provide a clear width of not less than 32 inches (813 mm). The maximum width of a swinging door leaf shall be 48 inches (1219 mm) nominal. The height of doors openings shall be not less than 80 inches (2032 mm).

Exceptions:

1. Door openings to storage closets less than 10 square feet (0.93 m²) in area shall not be limited by the minimum width.
2. Width of door ~~leafs~~ leaves in revolving doors that comply with Section ~~4008.1.4.1~~ 1010.1.4.1 shall not be limited.
3. *Exit access* doors serving a room not larger than 70 square feet (6.5 m²) shall be not less than 24 inches (610 mm) in door width.
4. Door closers and door stops shall be permitted to be 78 inches (1980 mm) minimum above the ~~door~~ floor.