

**NASME-1-A: Equivalent Safety Evaluation for Category D Non-Metallic Requirements for Piping not Associated with Pressure Vessel, Boilers, or Air Receivers (B31.3-2010 & 2012)**

**RECORD OF REVISION**

Rev	Date	Description	POC	RM
0	9/17/2014	Initial issue.	Ari Ben Swartz, <i>ES-EPD</i>	Larry Goen, <i>ES-DO</i>

Contact the Standards POC for upkeep, interpretation, and variance issues.

<b>Chapter 17</b>	<a href="#">Pressure Safety POC and Committee</a>
-------------------	---

This document is online at <http://engstandards.lanl.gov>

**This evaluation of risk is per Chapter 17, Section EXIST-1 (Qualitative Risk greater than 3)**

1. Applicable for B31.3 piping not including a pressure vessel, boiler, air receiver, or supporting piping.
2. Applicable only for NON - metallic piping systems.
3. This evaluation is for new pressure systems that allow workers to be in close proximity without additional shielding while the system is pressurized.
4. For severely cyclic system see specific code requirements.
5. A list of reputable manufacturers will be maintained by Engineering Services.
6. The “Equivalent Risk Evaluation” in the table below or the original paragraph in B31.3 may be followed. The equivalency is intended to provide an equivalent level of personnel safety to B31.3, not code compliance.
7. Applies to ML-4 only.

**Attachment NASME-1-A- Equivalent Safety Evaluation for Category D Non-Metallic Requirements for Piping not Associated with Pressure Vessel, Boilers, or Air Receivers**

Paragraph	<p align="center"><b>Category D Fluid Service Non Metallic Equivalency Evaluation (Within the allowance of notes above this table)</b></p>
<p align="center"><b>Title: Scope and Definitions</b></p>	
<p>A300 General Statements (b) Responsibilities</p>	<p>System Owner designs system, but must be approved by PSO B for safety check.</p> <p>Training will be developed for System Owners to perform pressure system designs. In the interim until the training is developed and implemented, system owners with PSO assistance and concurrence may serve as designers.</p> <p>PSO Duty Area B shall perform the role as Owner’s Inspector</p>
<p>300.1.3 Exclusions</p>	<p>Pressure systems will be inventoried with a system identification tag as defined in Section ADMIN-1. Those pressure systems that are excluded from B31.3 scope shall be declared Section GEN Att GEN-2 as follows:</p> <p>B31.3 excludes pressure systems if less than 15 psig, nonflammable, nontoxic, and not damaging to human tissues with a design temperature from –29°C (–20°F) through 186°C (366°F) B31 series does not apply.</p> <p>LANL pressure systems where the supply pressure is greater than 15 psig but have a relief device proven adequate to protect the system from over pressurization by calculation or flow testing to less than 15 psig, and is nonflammable, nontoxic, and not damaging to human tissues with a design temperature from –29°C (–20°F) through 186°C (366°F) are excluded.</p> <p>In order to maintain the LANL pressure system inventory a system identification tag shall be applied in accordance with ESM Chapter 17, Section 8.0, <i>System Identification Tag</i>, with the word Exempt on the tag.</p> <p>The regulator and relief device must be close coupled with no intervening stop valves and identified in accordance with ESM Chapter 17 requirements.</p> <p>A copy of a simplified system sketch and the documentation showing the system is adequately protected against overpressure shall be maintained as records, and must be managed per LANL P 1020, P 1020-1, and P 1020-2.</p> <p>Relief device retest frequency is a 5 year interval.</p>

**Attachment NASME-1-A- Equivalent Safety Evaluation for Category D Non-Metallic Requirements for Piping not Associated with Pressure Vessel, Boilers, or Air Receivers**

<b>Category D Fluid Service Non Metallic Equivalency Evaluation (Within the allowance of notes above this table)</b>	
<b>Title: Scope and Definitions</b>	
300.2 Definitions	<p>This table is <b>not</b> applicable to for Category M Fluid Service, Elevated Temperature Fluid Service, High Pressure Fluid Service, or High Purity Fluid Service (reference Section II Attachment II-3 for Category M fluids; contact the CPSO for other fluids not listed)</p> <p>Flammability limits are per Compressed Gas Association (CGA) P-23 (NFPA 55)</p> <p>Determination of flammability limit is per American Society for Testing and Materials (ASTM) E681-85, <i>Standard Test Method for Concentration Limits of Flammability of Chemicals</i>,</p>

<b>Title: Design</b>	
A301.1 Qualifications of the Designer	See above 300 General Statements (b) Responsibilities
A301.2.2 Required Pressure Containment or Relief	<p>As written for Category D Fluid Service., but using manufacturers' published rating for design pressure.</p> <p>Or protect personnel using other controls; engineering, administrative, and/or PPE as approved by the PSO as per ASME B&amp;PVC Section VIII Div. 1 UG-140 "OVERPRESSURE PROTECTION BY SYSTEM DESIGN "</p>
A301.3 Design Temperature	This paragraph does not apply if the pressure system is in a relatively constant temperature environment (+/- 10 F) and the temperature is less than 120 F (50C) (note this is to ensure there is no effect from thermal linear change).
A301.3.1 Design Minimum Temperature	Lowest allowable minimum design temperature is -20 F (-29 C).
A301.4 Ambient Effects	Does not apply if the pressure system is in a relatively constant temperature environment (+/- 10 F) and ambient temperature is less than 120 degree F.
A301.5 Dynamic Effects	Impact, wind, earthquake, vibration, discharge reactions are required to be evaluated and discounted or applied.
A301.6 Weight Effects	Live and dead loads are required to be evaluated and discounted or applied.

**Attachment NASME-1-A- Equivalent Safety Evaluation for Category D Non-Metallic Requirements for Piping not Associated with Pressure Vessel, Boilers, or Air Receivers**

A301.7 Thermal Expansion and Contraction Effects	Normally does not apply to pressure system is in a relatively constant temperature environment (+/- 10 F) and the temperature is less than 120 F (50C) (note this is to ensure there is no effect from thermal linear change)  Applies to pressure systems with appreciable thermal expansion or phase change induced volumetric expansion (increases of specific volume).
A301.8 Effects of Support, Anchor, and Terminal Movements	Restraints do not apply for whip hazard.
A301.9 Reduced Ductility Effects	Not applicable
302 Design Criteria	Note: This paragraph is for designing pipe and components, not for procurement of items offered for sale. If using reputable manufacturer's published ratings this paragraph does not apply.
A302.2.1 Listed Components Having Established Ratings	Listed items are recommended, but manufacturer's published ratings are acceptable.
A302.2.2 Listed Components Not Having Specific Ratings	Use reputable manufacturers' published ratings. A reputable manufacturers' listing will be maintain by Engineering Services.  Note: Institutional Evaluated Suppliers List (IESL) is not necessarily a listing of reputable manufacturers.
A302.2.3 Unlisted Components	Use reputable manufacturers' published ratings. A reputable manufacturers' listing will be maintain on the Engineering Services.
A302.3 Allowable Stresses and Other Stress Limits	Per design may consider other protective measures in order of precedence as follows: engineering controls (barriers, interlocks or controls), procedural controls (access control), and/or PPE.
A302.3.3 Limits of Calculated Stresses Due to Sustained Loads	Use B31.3 paragraph as written if applicable  Note: It is recommended that external loads be supported independent from the piping system.
A302.3.4 Limits of Calculated Stresses Due to Occasional Loads	Use B31.3 paragraph as written if applicable
A302.4 Allowances	Fluid will be evaluated and determined to be compatible for the service life of the system with the materials of construction and manufacturer's recommendations.

**Attachment NASME-1-A- Equivalent Safety Evaluation for Category D Non-Metallic Requirements for Piping not Associated with Pressure Vessel, Boilers, or Air Receivers**

<p>A304 PRESSURE DESIGN OF COMPONENTS</p> <p>A304.1 Straight Pipe</p>	<p>If LANL is designing or having a design made for a pressure component, the design shall comply with paragraph A304.1. The material shall meet A323.1 and must have a 3:1 factor of safety for materials not listed Table B1 (unlisted material).</p> <p>Note: This paragraph is for designing pipe and components, not for procurement of items offered for sale. If using reputable manufacturer's published ratings this paragraph does not apply.</p>
<p>A304.2 Curved and Mitered Segments of Pipe</p>	<p>If LANL is designing or having a design for a pressure component, the design shall comply with paragraph A304.2 The material shall meet A323.1 and must have a 3:1 factor of safety for materials not listed Table B1 (unlisted material).</p> <p>Note: This paragraph is for designing pipe and components, not for procurement of items offered for sale. If using reputable manufacturer's published ratings this paragraph does not apply.</p>
<p>A304.3 Branch Connections</p>	<p>If LANL is designing or having a design for a pressure component, the design shall comply with paragraph A304.3 The material shall meet A323.1 and must have a 3:1 factor of safety for materials not listed Table B1 (unlisted material).</p> <p>Note: This paragraph is for designing pipe and components, not for procurement of items offered for sale. If using reputable manufacturer's published ratings this paragraph does not apply.</p>
<p>A304.4 Closures</p>	<p>If LANL is designing or having a design for a pressure component, the design shall comply with paragraph A304.4 The material shall meet A323.1 and must have a 3:1 factor of safety for materials not listed Table B1 (unlisted material).</p> <p>Note: This paragraph is for designing pipe and components, not for procurement of items offered for sale. If using reputable manufacturer's published ratings this paragraph does not apply.</p>
<p>304.5 Pressure Design of Nonmetallic Flanges and Blanks</p>	<p>If LANL is designing or having a design for a pressure component, the design shall comply with paragraph 304.5 The material shall meet 323.1 and must have a 3:1 factor of safety for materials not listed Table A1 (unlisted material).</p> <p>Note: This paragraph is for designing pipe and components, not for procurement of items offered for sale. If using reputable manufacturer's published ratings this paragraph does not apply.</p>

**Attachment NASME-1-A- Equivalent Safety Evaluation for Category D Non-Metallic Requirements for Piping not Associated with Pressure Vessel, Boilers, or Air Receivers**

<p>A304.6 Reducers</p>	<p>If LANL is designing or having a design for a pressure component, the design shall comply with paragraph A304.6 The material shall meet A323.1 and must have a 3:1 factor of safety for materials not listed Table B1 (unlisted material).</p> <p>Note: This paragraph is for designing pipe and components, not for procurement of items offered for sale. If using reputable manufacturer’s published ratings this paragraph does not apply.</p>
<p>A304.7 Pressure Design of Other Components</p>	<p>Initial design consistent with the design criteria of ASME B31.3 shall be a hoop stress evaluation at the minimum wall thickness at the maximum part diameter (worst case hoop stress) showing the design meets or exceed the stress. Note use B31.3 allowable stress values with B31.3 equations.</p> <p>Substantiation of the above may be done by one of the 4 items below:</p> <p>Note: System design pressure may be used to evaluate the component as the design pressure</p> <ol style="list-style-type: none"> <li>1) For a simple part that has no stress intensification factors (notches, threads, pits, cracks, etc..) the minimum calculated hoop stress shall be 4x the design pressure (MAWP)</li> <li>2) Determine if the piping component was previously used in accordance with paragraph A304.7.2 (a)</li> <li>3) Pressure test to 4x the design pressure (at maximum design temperature).</li> <li>4) Perform Engineering Finite Analysis (FEA) in accordance with paragraph 304.7.2 (d) .</li> </ol>
<p>A305 Pipe</p>	<p>Paragraph is required to be evaluated and discounted or applied</p>
<p>A306 FITTINGS, BENDS, MITERS, LAPS, AND BRANCH CONNECTIONS</p>	<p>If LANL is designing or having a design for a pressure component, the design shall comply with paragraph A306. The material shall meet A323.1 and must have a 3:1 factor of safety for materials not listed Table A1 (unlisted material).</p> <p>Note: This paragraph is for designing pipe and components, not for procurement of items offered for sale. If using reputable manufacturer’s published ratings this paragraph does not apply.</p>

**Attachment NASME-1-A- Equivalent Safety Evaluation for Category D Non-Metallic Requirements for Piping not Associated with Pressure Vessel, Boilers, or Air Receivers**

<p>A307 VALVES AND SPECIALTY COMPONENTS</p>	<p>If LANL is designing or having a design for a pressure component, the design shall comply with paragraph A307. The material shall meet A323.1 and must have a 3:1 factor of safety for materials not listed Table A1 (unlisted material).</p> <p>Note: This paragraph is for designing pipe and components, not for procurement of items offered for sale. If using reputable manufacturer's published ratings this paragraph does not apply.</p>
<p>A308 FLANGES, BLANKS, FLANGE FACINGS, AND GASKETS</p>	<p>If LANL is designing or having a design for a pressure component, the design shall comply with paragraph A308. The material shall meet A323.1 and must have a 3:1 factor of safety for materials not listed Table A1 (unlisted material).</p> <p>Note: This paragraph is for designing pipe and components, not for procurement of items offered for sale. If using reputable manufacturer's published ratings this paragraph does not apply.</p>
<p>A309 BOLTING</p>	<p>If LANL is designing or having a design for a pressure component, the design shall comply with paragraph A309. The material shall meet A323.1 and must have a 3:1 factor of safety for materials not listed Table A1 (unlisted material).</p> <p>Note: This paragraph is for designing pipe and components, not for procurement of items offered for sale. If using reputable manufacturer's published ratings this paragraph does not apply.</p>
<p>A310 GENERAL</p>	<p>Use B31.3 paragraph as written.</p>
<p>A311 Bonded Joints in Plastic</p>	<p>Welding or Brazing shall be done in accordance with ESM Chapter 13 <i>Welding, Joining, and NDE</i> [Non-destructive examinations (NDE)].</p> <p>Note: Qualitative Risk evaluated per ESM Chapter 17 Att GEN-4 shall be controlled to QR number of 4 or higher per Table GEN-4-4, Qualitative Risk (QR) Determination</p> <p>Follow manufacturers' instructions for assembly of PVC solvent welded joints.</p>
<p>A311.2 Specific Requirements</p>	<p>Welding or Brazing shall be done in accordance with ESM Chapter 13 <i>Welding, Joining, and NDE</i>.</p>
<p>A312 Flanged Joints</p>	<p>Use B31.3 paragraph as written for Category D Fluid Service:</p> <p>"The designer should consult the manufacturer for ratings of flanged joints in nonmetallic piping and in piping lined with nonmetals."</p>
<p>A313 Expanded Joints</p>	<p>Use B31.3 paragraph as written for Category D Fluid Service</p>

**Attachment NASME-1-A- Equivalent Safety Evaluation for Category D Non-Metallic Requirements for Piping not Associated with Pressure Vessel, Boilers, or Air Receivers**

A314 Threaded Joints	Use B31.3 paragraph as written for Category D Fluid Service
A315 Tubing Joint	Use B31.3 paragraph as written for Category D Fluid Service
A316 CAULKED JOINTS	Use B31.3 paragraph as written for Category D Fluid Service.
A318 Special Joints	As written for Category D Fluid Service, and evaluate in accordance with A304.7.2 in this table.  NOTE: Gland here does not mean Swagelok gland fitting.
A319 Piping Flexibility	The design temperature is from -29°C (-20°F) through 186°C (366°F) Paragraph is required to be evaluated and discounted or applied  When pressure systems are fabricated and used at relatively constant temperature conditions (+/- 10 F), and fluid temperature is also held within the same range this paragraph is satisfied.
A320 Analysis of Sustained Loads	Piping is not to be used to support equipment (not a piping component). Paragraph is required to be evaluated and discounted or applied.  Piping supports may be in accordance with LANL Master Specification 22 0529 for all Category D Fluid Service pressures.  If additional support is required see 321.
A321 Piping Supports	Use B31.3 paragraph as written in 321.1.2 “simple calculations and engineering judgment”
A322 SPECIFIC PIPING SYSTEMS	Use B31.3 paragraph as written.
A322 SPECIFIC PIPING SYSTEMS	Use B31.3 paragraph as written  Pressure systems with vessels, air receivers or boilers require an ASME Stamped and approved relief device protecting the vessel, air receiver, or boiler.  Existing piping relief devices may be used if they are stamped and the vessel cannot be pressurized through any other path or means.  Piping relief is not required to be V stamped if no code stamped item (pressure vessel, boiler, or air receiver) is present.

**Attachment NASME-1-A- Equivalent Safety Evaluation for Category D Non-Metallic Requirements for Piping not Associated with Pressure Vessel, Boilers, or Air Receivers**

<b>Title: Materials</b>															
A323 GENERAL REQUIREMENTS	<p>Use listed materials for example:</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="padding: 2px;">Acrylonitrile-butadiene-styrene plastics</td> <td style="padding: 2px;">ABS</td> </tr> <tr> <td style="padding: 2px;">Chlorinated poly(vinyl chloride)</td> <td style="padding: 2px;">CPVC</td> </tr> <tr> <td style="padding: 2px;">Perfluoro (alkoxyalkane)</td> <td style="padding: 2px;">PFA</td> </tr> <tr> <td style="padding: 2px;">Polypropylene PP, Poly(vinyl chloride)</td> <td style="padding: 2px;">PVC</td> </tr> <tr> <td style="padding: 2px;">Poly(vinylidene chloride)</td> <td style="padding: 2px;">PVDC</td> </tr> <tr> <td style="padding: 2px;">Poly(vinylidene fluoride)</td> <td style="padding: 2px;">PVDF</td> </tr> <tr> <td style="padding: 2px;">Polytetrafluoroethylene</td> <td style="padding: 2px;">PTFE</td> </tr> </table> <p>Additional listed materials are in B31.3 Appendix B. This evaluation does not apply to Test Articles.</p>	Acrylonitrile-butadiene-styrene plastics	ABS	Chlorinated poly(vinyl chloride)	CPVC	Perfluoro (alkoxyalkane)	PFA	Polypropylene PP, Poly(vinyl chloride)	PVC	Poly(vinylidene chloride)	PVDC	Poly(vinylidene fluoride)	PVDF	Polytetrafluoroethylene	PTFE
Acrylonitrile-butadiene-styrene plastics	ABS														
Chlorinated poly(vinyl chloride)	CPVC														
Perfluoro (alkoxyalkane)	PFA														
Polypropylene PP, Poly(vinyl chloride)	PVC														
Poly(vinylidene chloride)	PVDC														
Poly(vinylidene fluoride)	PVDF														
Polytetrafluoroethylene	PTFE														
A323.1.1 Listed Materials.	Use B31.3 paragraph as written.														
A323.1.2 Unlisted Materials	<p>Prior to using an unlisted material the chemistry, physical and mechanical properties, method and process of manufacture, heat treatment, and quality control must be known as required by A323.1.</p> <p>Note: This paragraph is for designing pipe and components, not for procurement of items offered for sale. If using reputable manufacturer’s published ratings this paragraph does not apply. The Designer is cautioned that materials must be suitable for the application and must be evaluated in accordance with A323.1 if necessary to determine the suitability of the material.</p>														
A323.1.3 Unknown Materials.	Don’t use unknown materials.														
A323.1.4 Reclaimed Materials.	Use B31.3 paragraph as written.														
A323.2 Temperature Limitations	Note: The minimum [–29°C (–20°F)] and maximum temperature as shown in the definition of Category D Fluid Service does not necessarily apply, and must be verified as required by A323.2														

**Attachment NASME-1-A- Equivalent Safety Evaluation for Category D Non-Metallic Requirements for Piping not Associated with Pressure Vessel, Boilers, or Air Receivers**

A323.2.1 Upper Temperature Limits, Listed Materials.	Materials shall have test results or manufacturers supplied data at or above the highest expected service temperature.
A323.2.2 Lower Temperature Limits, Listed Materials	Materials shall have test results or manufacturers supplied data at or below the lowest expected service temperature.
A323.2.3 Temperature Limits, Unlisted Materials.	<p>Use B31.3 paragraph as written. To verify the temperature limits of the unlisted material meet the requirements of the design temperature.</p> <p>Note: This paragraph is for designing pipe and components, not for procurement of items offered for sale. If using reputable manufacturer’s published ratings this paragraph does not apply. The Designer is cautioned that materials must be suitable for the temperature and must be evaluated in accordance with 323.2.3 if necessary to determine the suitability of the material.</p>
A323.2.4 Verification of Serviceability	Use B31.3 paragraph as written.
A323.4 Fluid Service Requirements for Non-Metallic Materials 323.4.1 General.	Use B31.3 paragraph as written.
A323.4.2 Specific Requirements	Use B31.3 paragraph as written.
A323.4.3 Piping Lined With Nonmetals.	Use B31.3 paragraph as written.
A323.5 Deterioration of Materials in Service	Designer is required to design the pressure system for the service life of the system and consider material compatibility.

**Attachment NASME-1-A- Equivalent Safety Evaluation for Category D Non-Metallic Requirements for Piping not Associated with Pressure Vessel, Boilers, or Air Receivers**

A325 MATERIALS — MISCELLANEOUS	Use B31.3 paragraph as written.
326 DIMENSIONS AND RATINGS OF COMPONENTS	Use components as defined in the code or use reputable manufacturers' published ratings. A reputable manufacturers' listing will be maintained on the Engineer Services website. Note: Institutional Evaluated Suppliers List (IESL) is not necessarily a listing of reputable manufacturers.
A326.1 Dimensional Requirements	Apply B31.3 paragraph as written (see A301.2.2)
A326.4 Abbreviations in Table A326.1 and Appendix B	Apply B31.3 paragraph as written
A327 GENERAL	Use B31.3 paragraph as written.
A328 BONDING OF PLASTICS	Not required for a low risk pressure system (ESM Chapter 17 Pressure Safety, Table E-3 Qualitative Risk (greater than 3))
A329 FABRICATION OF PIPING LINED WITH NONMETALS	Apply B31.3 paragraph as written (see A301.2.2), or as per the variance VAR-2013-060 B31.3 – 2010 & 2012 Category D Requirements
A332 BENDING AND FORMING	Apply B31.3 paragraph as written (see A301.2.2), or as per the variance VAR-2013-060 B31.3 – 2010 & 2012 Category D Requirements
A334 JOINING NONPLASTIC PIPING	Use B31.3 paragraph as written.
A335 ASSEMBLY AND ERECTION	Assemble in accordance with the manufacturer's requirements

**Attachment NASME-1-A- Equivalent Safety Evaluation for Category D Non-Metallic Requirements for Piping not Associated with Pressure Vessel, Boilers, or Air Receivers**

<p>A340 INSPECTION 340.1 General</p>	<p>Paragraph 340 applies in its entirety. PSO Duty Area B will be the Owner’s Inspector Owner’s Inspector will be knowledgeable with the pressure system of interest.</p>
<p>340.2 Responsibility for Inspection</p>	<p>Use B31.3 paragraph as written.</p>
<p>340.3 Rights of the Owner’s Inspector</p>	<p>Use B31.3 paragraph as written.</p>
<p>340.4 Qualifications of the Owner’s Inspector</p>	<p>See paragraph 300; PSO Duty Area B will act as the Owner’s Inspector or equivalent.</p>
<p>A341 EXAMINATION</p>	<p>Use B31.3 paragraph as written.</p>
<p>A342 Examination Personnel</p>	<p>Examiners shall have training and experience commensurate with the needs of the specified examinations. In the interim perform examination as defined in VAR-2012-008 while variance is in effect.</p> <p>Bubble leak testing Examiners will take a bubble leak test qualification course "Category D Requirements for Piping not associated with PV, Boilers, or Air Receivers", pass a quiz for material comprehension (80%), and be approved by a PSO B. The quiz result will be retained on UTrain.</p> <p>The examiner will then work performing leak testing (bubble leak and hydrostatic leak test). The PSO B will maintain a list of the approved examiners during the interim or if ASNT-TC-1A certification is not desired.</p> <p>If the examiner desires to be ASNT-TC-1A certified they must 1) pass a written general exam, 2) pass a written specific exam, 3) pass a hands-on practical exam, and 4) provide documentation of sufficient hours performing the examination.</p> <p>Note: Level II or higher ASNT-TC-1A must comply with ESM Chapter 13 application and documentation.</p>
<p>A343 Examination Procedures</p>	<p>Use B31.3 paragraph as written.</p>

**Attachment NASME-1-A- Equivalent Safety Evaluation for Category D Non-Metallic Requirements for Piping not Associated with Pressure Vessel, Boilers, or Air Receivers**

A344 Types of Examination	Use B31.3 paragraph as written.
A345 TESTING	<p>Precautions in Appendix F, para. FA323.4 Material Considerations — Nonmetals should be considered.</p> <p>Owner has elected to use Initial Service Leak Test (additional testing may be required by the Designer).</p> <p>See variance VAR-2011-032.1 for vacuum rate of rise and inert gas referee test gas.</p> <p>Note: Be aware of the ramifications of using high molecular weight gases to test system for lower molecular weight gas. The engineering best practice is to use a lower or equal weight molecular weight gas as the referee test gas except for hydrogen where helium is accepted.</p>
A346 RECORDS	<p>Required information is as follows:</p> <ul style="list-style-type: none"> <li>• Sketch,</li> <li>• Component list (manufacturer, model number, pressure rating, FM07 information)</li> <li>• Calculation</li> <li>• Relief device/flow calc.</li> <li>• Examinations</li> <li>• Inspections</li> </ul> <p>Electronic copy loaded into a master site repository.</p>